



Certificate of Compliance

Certificate: 80076239 **Master Contract:** 156549 (LR 102355)

Project: 80109715 **Date Issued:** 2022-02-23

Issued To: MP Husky LLC.
1370 Old Stage Road
Simpsonville, South Carolina, 29681
United States

Attention: Doug Adams

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Mike W. Gryschuk
Mike W. Gryschuk, C.E.T.

PRODUCTS

CLASS 4681 09 - WIREWAYS AND BUSWAYS - Cablebus

CLASS 4681 89 - WIREWAYS AND BUSWAYS - Cablebus - Certified to US Standards

Cablebus System Series ACB, Class B, rated 6000A max at 30°C Ambient, 35kV max, 60Hz, 100kArms max Short-Circuit.

APPLICABLE REQUIREMENTS

CSA/ANSI Std. C22.2 No. 273-19, 2nd Ed - Cablebus

Notes:

Products certified under Class 4681 09 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

